



WSC 310 – WSC 320

Declaration of Performance / Leistungserklärung / Déclaration de Performance / Ydeevnedeklaration

(DoP)

 Notified Body: 0402
WindowMaster A/S, Skelstedet 13, DK-2950 Vedbæk 15 (0402-CPR-SC0754-15)
Electrical power supply equipment, intended to be used in smoke and heat controls systems. Elektrische Versorgungsgeräte, für den Einsatz in Rauch- und Wärmeabzugsanlagen. Équipement d'alimentation électrique destiné à être utilisé dans les systèmes de désenfumage. Elektrisk forsyningsudstyr, for anvendelse i forbindelse med brandventilation.
System of assessment and verification of constancy of performance: System 1 System zur Bewertung und Überprüfung der Leistungsbeständigkeit: System 1 Système d'évaluation et de vérification de la constance des performances: Système 1 System til vurdering og verifikation af ydeevnens konstans: System 1
EN 12101-10: 2005 + AC 2007 Operation class / Funktionsklasse / Classe d'opération / Funktionsklasse: A Environmental class / Umgebungsbedingungsklasse / Classe environnementale / Driftbetingelsesklasse: 1 IP rating / IP-Schutzart / Protection IP / Kapslingsklasse: IP 54 Interruption time / Unterbrechungszeit / Temps d'interruption / Brydetid: < 2,0 sec Minimum Standby period / Min. Notstromversorgungszeit / Temps d'alimentation d'urgence min. / Min. nødstrømforsyningstid: 72h Maximum capacity / Maximum Kapazität / Capacité maximale / Max kapacitet: WSC 310: 2x7Ah, WSC 320: 2x12Ah Input / Versorgungsspannung / Tension d'alimentation / Forsyningsspænding: 1 x 230 VAC (±10%) single phase 47-63 Hz Output current (Imax b)/ Ausgangsstrom (Imax b) / Courant de sortie (Imax b) / Udgangsstrøm (Imax b): WSC 310: 10A, WSC 320: 20A Output voltage / Ausgangsspannung / Tension de sortie / Udgangsspænding: 24 VDC ±15%
<p>The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of WindowMaster International A/S.</p> <p>Die Leistung des vorstehenden Produkts entspricht den erklärten Leistungen. Für die Erstellung der Leistungserklärung im Einklang mit der Verordnung (EU) Nr. 305/2011 ist allein WindowMaster International A/S verantwortlich.</p> <p>Les performances du produit identifié ci-dessus sont conformes à l'ensemble des performances déclarées. Cette déclaration de performance est émise, conformément au règlement (UE) n ° 305/2011, sous la seule responsabilité de WindowMaster International A/S.</p> <p>Ydeevnen for den vare, der er anført ovenfor, er i overensstemmelse med den deklarerede ydeevne. Denne ydeevnedeklaration er udarbejdet i overensstemmelse med forordning (EU) nr. 305/2011 på eneansvar af WindowMaster International A/S.</p> <p>WindowMaster International A/S:  (Nicolaj Rasmussen Shabtai, Chief Product Officer)</p> <p>Skelstedet 13, DK-2950 Vedbæk, 14th March 2019 Declaration no. WSC 310/320_DoP_201903</p>

DK +45 4567 0300
 UK +44 (0) 1536 510990
 DE +49 (0) 5221 6940 -500 Vertrieb / -650 Technik
 CH +41 (0) 62 289 22 22
 NO +47 33 99 71 00
 Other markets +45 4567 0300

info.dk@windowmaster.com
 info.uk@windowmaster.com
 info.de@windowmaster.com
 info.ch@windowmaster.com
 info.no@windowmaster.com
 info@windowmaster.com

www.windowmaster.com

**UK
CA**

Supplied by

WindowMaster Control Systems Ltd

Lamport Close

Kettering Parkway- Kettering

Northants NN15 6XY

Tel.: +44 1536 614070

Fax: +44 1536 614071

info@windowmaster.co.uk

DK +45 4567 0300
UK +44 (0) 1536 510990
DE +49 (0) 5221 6940 -500 Vertrieb / -650 Technik
CH +41 (0) 62 289 22 22
NO +47 33 99 71 00
Other markets +45 4567 0300



info.dk@windowmaster.com
info.uk@windowmaster.com
info.de@windowmaster.com
info.ch@windowmaster.com
info.no@windowmaster.com
info@windowmaster.com

www.windowmaster.com

WSC 310 – WSC 320

Declaration of Performance

(DoP)

 Approved Body: 1720
WindowMaster A/S, Skelstedet 13, DK-2950 Vedbæk (1720-CPR-0242)
Electrical power supply equipment, intended to be used in smoke and heat controls systems.
System of assessment and verification of constancy of performance: System 1
EN 12101-10: 2005 + AC 2007 Operation class: A Environmental class: 1 IP rating: IP 54 Interruption time: < 2,0 sec Minimum Standby period: 72h Maximum capacity: WSC 310: 2x7Ah, WSC 320: 2x12Ah Input: 1 x 230 VAC (±10%) single phase 47-63 Hz Output current (I _{max b}): WSC 310: 10A, WSC 320: 20A Output voltage: 24 VDC ±15%
The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with CPR - Construction product regulation 2019, under the sole responsibility of WindowMaster International A/S.
WindowMaster International A/S:  (Nicolaj Rasmussen Shabtai, Chief Product Officer)
Skelstedet 13, DK-2950 Vedbæk, 21 March 2022